

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

May 29, 2013

DESIGN HOMES, INC. MICHAEL MASON 600 N MARQUETTE RD PO BOX 239 PRAIRIE DU CHIEN WI 53821

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: DESIGN HOMES, INC.

Product Name: PREFABRICATED PLUMBING

Model Number(s): PLB 19 Product File No: 20130142

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2018.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means
 concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in
 a modular building component, which will not be visible for inspection when delivered to the final site of
 installation.
- Please send in current drawings with a copy of this approval letter.

This approval supersedes the approval issued on October 13th, 2008 under product file number 20080581.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 20130142_approval letter (2).DOC

DESIGN HOMES, INC. Page 2 May 29, 2013

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-266-2602 Fax
tim.lamb@wi.gov E-mail